

PAT-15 PNEUMATIC TIMER ASSEMBLY



FEATURES:

- MEETS ALL EXPLOSION PROOF REQUIREMENTS.
- NO ELECTRICAL CONNECTIONS.
- ADJUSTABLE TIME RANGE:
1 SEC.-5 MIN. "ON"
1 SEC.-5MIN. "OFF"
- AIR SUPPLY: 30-80 PSI
- OPERATING TEMPERATURES:
MINIMUM: 35°F
MAXIMUM: 175°F

INSTALLATION:

Mount in vertical position only.
A manual valve should be installed ahead of timer for system shut-off.
Both exhausts (3/4 & 1/8") must be left open.
Mufflers may be installed by customer.
Input must be filtered (non-lubricated air).
Lubricator must be installed after timer.

OPERATION:

Turn manual valve to the "ON" position.
Adjust "ON" time cycle by turning bottom screw until required time is obtained.
Clockwise increases the cycle. Do not jam adjusting screw to bottom.
Repeat the above step to adjust the "OFF" cycle.
Observe vibrator cycles and adjust if required.

